

June 18, 2021

Attn: Mr. David Paulo Sr.
Fire Retardant Coatings of Texas, LLC
1150 Blue Mound Road West #403
Haslet, TX 76052

(817) 710-5233
david@frctexas.com

RE: FX LUMBER GUARD/FX LUMBER GUARD XT
Fire Retardant Treated Wood Sheathing
Code Compliance Alternate
New York City, NY

Project No. 19389.01

Dear Mr. Paulo Sr.:

I have reviewed the testing performed on the FX Lumber Guard/FX Lumber Guard XT product by Fire Retardant Coatings of Texas. The testing was performed by Intertek Building & Construction between August 4, 2015 and January 21, 2019 using ASTM D2369, ASTM D4017, ASTM D5516, ASTM E2768, ASTM E84, and AWPA E12 standards. Testing was performed at Intertek facilities in York, Pennsylvania, Elmendorf, Texas, and Middleton, Wisconsin.

Based on the NYC Building Code 2014 and its adoptions with amendments to the International Building Code (IBC, 2009) Section 2303.2.2, plywood and OSB treated with FX Lumber Guard/FX Lumber Guard XT, with all surfaces of the wood product being covered for permanent protection, is an acceptable alternate application in the City of New York City, New York to Fire Retardant Treated plywood/OSB.

Should you have any questions relating to this matter please contact me at your convenience.

Sincerely,



Allan T. Myket, P.E.
amyket@structuralenginuityinc.com



6/18/2021

THAT IT IS A VIOLATION OF THIS LAW FOR ANY PERSON, UNLESS HE IS ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER OR LAND SURVEYOR, TO ALTER AN ITEM IN ANY WAY. IF AN ITEM BEARING THE SEAL OF AN ENGINEER OR LAND SURVEYOR IS ALTERED, THE ALTERING ENGINEER OR LAND SURVEYOR SHALL AFFIX TO THE ITEM HIS SEAL AND THE NOTATION "ALTERED BY" FOLLOWED BY HIS SIGNATURE AND THE DATE OF SUCH ALTERATION, AND A SPECIFIC DESCRIPTION OF THE ALTERATION.